

MS No.: MS/014/022

Rev.: 02

Date: 10 APR 2014

The Engineer:

**ATKINS**

The Employer:



Arabtec Property Investment LLC

The Contractor:



Arabtec Construction LLC

Project: **5127461 - P17 Mixed Use Tower Development and Multi-Storey Car Park**

# Material Submittal

Ref. No. MS/ATC/022

Rev. No. 00

Originator of Submittal: AL GHURAIR CONSTRUCTION

Date: 10-Apr-14

Authorised Sign:

Reqd. By: 24-Apr-14

## Material Detail

## List of Enclosure

(Tick the Related Box)

### Item Description

Specs. Reference	D30
BOQ Reference	Bill no. 2 Page 2/3 Item A & B Piling Works
Drwg. Reference	
Material Specified	-
Material Proposed	Plastic Spacers 75mm dia. - Closed Type BPC75 & Open Type BPC75C (for piling works)
Manufacturer / Supplier	Bartek System
Remarks	Trade Licence, ISO certificate and previous approvals attached

- Vendor's Technical Literature
- Compliance Statement
- Previous Test Results
- Copy of the Related Specs.
- Samples with Sample Tag
- List of Previous Projects Done
- Others (Specify):

Contractor Statement: We certify that the material submitted herewith has been reviewed in details and is in compliance with the contract drawings and specifications except as otherwise stated hereabove.

Contractor Sign: Yasin El Khatib

Date: 10-4-14


ATKINS Received Sign:

Date:

Ref.No 5127461/R11-161

### ATKINS Engineer's Comments:

we advice to use conc spacers AT top & Bottom



Reviewed By:

Date:

### ATKINS Resident Engineer's Comments

- Code A - Approved
- Code B - Approved As Noted
- Code C - Not Approved, Resubmit
- Code D - Information, Record
- Code E - Incomplete, Resubmit

ATKINS RE Sign: AMR AMIN

Date: 15 APR 2014

Ref.No 5127461/R10-

Contractor Received Sign:

Date:

Corrections or comments made relative to submittals during this review do not relieve the contractor from compliance with the contract requirements and specifications. This check is only for review of general conformance with the design concept of the project and general compliance with the information given in the contract documents.

10 APR 2014

**RECEIVED**  
10 APR 2014