



ARCHITECTURAL
CONSULTING
GROUP
دار الاستشارات المعمارية

Material Approval Request



Project Title : BATEEN MARINA RESORT DEVELOPMENT

Consultant : Architectural Consulting Group (ACG)

Address : Abu Dhabi, UAE

Contractor : Dutch International Contracting

Submittal Ref No	Revision	Date of Submittal
MAR-2396-4	0	31 / 12 / 2014

Material Title : Steel Coupler	Drawing Ref No:	B o Q Ref No:
-----------------------------------	-----------------	---------------

No	Description - Specified	Description - Proposed
1	Steel Coupler (Technical Date Sheet attached with sample)	Model :CCHP25300M Length : 150mm / External Dia : 45mm/ Thread Pitch : 7.2mm / Extrusion Pass : 3 x2 Pressure strength : 53MPa

Attachments:	1- Certificate and test report	2- specification Data sheet	- Samples 2nos
--------------	--------------------------------	-----------------------------	----------------

ACG ARCHITECTURAL CONSULTING GROUP
10847 - BATEEN MARINA RESORT DEVELOPMENT

INCOMING

REF: MAR-2396-4
DATE: 31/12/14

COPY	ACT	INFI
PM		
AR		
ST		
ME		
EE		
ID		
TIME:		

Prepared by (Siraj) :	Approved for Submittal by Project Manager	Received by Consultant
Reviewed by Project Manager. Name: Eng.Fadi Naem. Signature: <i>[Signature]</i>	Name: Signature:	Date: Signature: Stamp:

For Use By Consultant:
Comments:

1. approved according to the attached test results.
2. QA/QC and safety measures to be adhered to.
3. As Built for the location where coupler will be used to be provided.

Approval Status	A Approved <input checked="" type="radio"/>	B Implement Exceptions Noted	C Revise & Resubmit	D Rejected
Consultant Name:	Signature: <i>[Signature]</i>	Date:		

Note: The above comments / or approval does not relieve the Contractor from his obligation in the contract to ensure conformance to the specification. Any Deviations found subsequent to the approval are to be corrected by the contractor to the satisfaction of the Client / Consultant.

CC: Client: 1 copy (With All Attachments) (Cover Page only)

Received By the Contractor - One copy with Attachment Name: <i>Siraj</i>	Signature: <i>[Signature]</i>	Date: 12 JAN 2015
---	-------------------------------	-------------------

Dutch International Contracting Co. LLC
Tel: 02 6661005, Fax: 02 6661200, P.O.Box: 83459 - Abu Dhabi - U.A.E.

RECEIVED

Section reserved for Contractor use only :

ACG ARCHITECTURAL CONSULTING GROUP
10847 - BATEEN MARINA RESORT DEVELOPMENT

31 DEC 2014

RECEIVED

ACG ARCHITECTURAL CONSULTING GROUP
10847 - BATEEN MARINA RESORT DEVELOPMENT

APPROVED

APPROVED AS NOTED

NOT APPROVED

Any approval does not Relieve the contractor of his responsibilities under the contract.