



Employer:
Roads Department
P.O.Box 118899- Dubai, U.A.E.

Engineer:
Parsons Overseas Limited.
P.O. Box -9123- Dubai, U.A.E.

Contractor:
China State Construction Engrg.
P.O.Box-63932 - Dubai, U.A.E

PROJECT : R1041
DUBAI PARKS ACCESS FROM SHEIKH ZAYED ROAD

MATERIAL SUBMITTAL

No. MS-080

NEW SUBMITTAL



RE-SUBMITTAL



Document No.:

Date: 23-08-2015

B.O.Q. ITEM REF.

NIL

MATERIAL DESCRIPTION

Bartek Systems Pile Cage 100mm Cover (BPCC-220)
Circular Concrete Spacer

SPECIFICATION CLAUSE REF.

General Specification Volume 2 Part 1 Section 8 Clause 8/9.3

DRAWINGS REF.

SG-1.1A

MANUFACTURER

Ozone International Building Material Trading, Sharjah

LOCAL SUPPLIER

Ozone International Building Material Trading, Sharjah

Received by (POL)

Stamp for receipt (CSCEC)

ENCLOSURES:

- B.O.Q. Pages
- Specifications
- Drawings /Sketch
- Trade License
- Sample Submitted
- Catalogue/Brochure
- Test Reports
- ISO Certificate
- List of jobs.

Approval requested by:

Name: Ahmed Saad

Signature:  | Date: 22/08/15

MATERIAL ENG.


Source approved. Subject to the comments on attached sheet

ADDITIONAL COMMENTS

For Client / Engineer:

Name:

Signature:



Date: 26/8/15

Status:

- Approved
- Approved Except as noted
- Revise & Re-submit
- Not Approved
- Sample is Required

MATERIALS APPROVAL FORM

Material Submission No: **080**

Client : Roads & transport Authority

Consultant : Parsons Overseas Limited

Previous Submission Ref:
(If Resubmitted)

Contractor : China State Construction Engrg.

Project : Contract R1041 - Dubai Parks Access From Sheikh Zayed Road

DESCRIPTION:

**Bartek Systems Pile Cage 100mm Cover (BPCC-220)
Circular Concrete Spacer**

Date of Submission : 23-Aug-15

Date of Approval Required by : ASAP

Bill No. Ref. : Nil

Specification Ref : General Specification Volume-2 Part-I, Section 8 Clause 8/9.3.

Construction Drawing : SG-1.1A

Name and Address of Manufacturer : M/s Ozone International Building Material Trading, Sharjah

Local Agent : M/s Ozone International Building Material Trading, Sharjah

Technical Literature : Attached

Samples : -

CONSULTANT

APPROVED REJECTED APPROVED AS NOTED

Since the source has been already approved by RTA for project R989 & R983, recommended for approval for R-1041 subject to the following.

- 1) Material to comply with General Specification Volume-2 Part-I, Section 8 Clause 8/9.3.
- 2) Sample delivered at site to be tested at Independent Lab and result to comply with specification requirements before use.
- 3) To be inspected before use

[Handwritten Signature]
2-3/8



CLIENT

APPROVED REJECTED APPROVED AS NOTED

As Noted

[Handwritten Signature]

25/8/15

AUTHORIZED SIGNATURE

DATE:

Notes:

1. DM no objection does not relieve either the Consultant or Contractor of their responsibilities under the Consultancy Agreement or Contract.
2. All relevant test results required by the specification to be attached.