

Viceroy Hotels Resorts and Residences on PJTRH01 at Palm Jumeirah

MATERIAL DATA APPROVAL FORM

Note: Any approval does not relieve the Contractor from his responsibilities outlined in the Contract Documents.

From Bid Pack No. : _____ MAF NO : CSC/VHR/MAR-STR/026-00
 Contract No. : _____ Date : 15 December -2013
 Contractor's Name : China State Construction Engineering Corp. (Middle East) (LLC)
 To : Engineering Consultants Group (ECG) cc : _____

MATERIAL DESCRIPTION : Spacer Blocks (Concrete Spacer) Lishong 06/01/2014


MANUFACTURER/SUPPLIER : Bartek Systems / Ozone International Bldg. Materials

COUNTRY OF ORIGIN : UAE

CONTRACT SPECIFICATION REQUIREMENTS :

CC/22 : 6.25 Bending and Fixing Reinforcements

(1 SOFT COPY)



Does the material totally comply with Contract requirements? YES / NO

If No, identify non-compliance (minor only) and proposed alternative to contract requirement.

CONTRACTOR'S REPRESENTATIVE: NAME (PRINT): Tan Eng Wan, SPM SIGNATURE : [Signature]


ENGINEER'S COMMENTS :

Approved subject to The contractor must follow all the required steel cover ^{dimensions} as per mentioned in the approved dwgs and Specs.
To provide renewed Trading Register Certificate for Ozone company

Approved Approved as noted above Not Approved

A/E : _____
DATE : 6/1/2014

CONTRACTOR RECEIVED BY : _____
DATE : _____



Original : CONTRACTOR
CC : Employer Representative
 Other OTHER